

LOCATION 2702 Davis Park Rd. CITY EASTONIA
 BETWEEN Penny Park Dr. STREET & Cedar Oak STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>80'</u>	<u>12-20-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>50'</u>			

ENTERS: 2702 BRANCHED INTO: 0

TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 110' S of Cor Cedar Oak

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 6" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1964

DEPTH: 3 FT. 6 IN. LOCATION 14' E of Cor Davis Park Rd.

"A" P/S READING 600 TOTAL ANODES 1# _____ 17# 1 L.R. # 645032

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>		

