

LOCATION 2120 DAWNSHIRE CITY Coastal

BETWEEN Rudd STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>60</u>	<u>8'</u>		<u>Retired</u>	<u>9-17-98</u>
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 2120 BRANCHED INTO: 0

TAP SIZE: 3/4 Ser PRESSURE 600 PSI _____ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ED

MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 2 FT. 6 IN. LOCATION

"A" P/S READING 1.4 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R/S</u>	<u>1.4</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY