

LOCATION 4300 Dawnwood Dr CITY GASTONIA

BETWEEN Frostwood Dr. STREET & Hightwood Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>95'</u>	<u>10-4-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>50'</u>			

ENTERS: 4300 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 137' SW. of center of

Frostwood Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstetter

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED _____

DEPTH: 3 FT. 0 IN. LOCATION 17' NW. of center of Dawnwood Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 672966

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY