


LOCATION	4403 Dawnwood Dr		CITY	Gastonia		
BETWEEN	Coachwood Ln		STREET B	Knightwood Dr.		STREET
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3 1/4"	P	74'	2-26-99		
MAIN TO PROP. LINE	3 1/4"	P	5'			
PROP. LINE TO BLDG.	3 1/4"	P	69'			
ENTERS:	4403		BRANCHED INTO:			
TAP SIZE:	1/2	PRESSURE	60	P.S.I.	INCHES W.C.	LOCATION 288' W. of
						Center of Knightwood Dr.
PRESSURE TEST:	@	100	psi	For	1 1/4	Hrs. By S. G.
MAIN - SIZE	4"	C.I.	BARE STEEL	COATED STEEL	PLASTIC	YEAR INSTALLED
DEPTH:	3 Ft.	0	In.	LOCATION	15' N. of center of Dawnwood Dr.	
"A" P/S READING	P	TOTAL ANODES	1# 0	17# 0	L.R. #	145814
REMARKS:						



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	