

LOCATION 4420 Dawnwood Dr CITY Crofton

BETWEEN Coachwood Dr STREET & Knightwood Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	104'	2-5-98		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	64'			

ENTERS: 4420 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 4420' E of center of Coachwood Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstetter

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH: 3 FT. 0 IN. LOCATION 19' N. of center of Dawnwood Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 65908

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY