

LOCATION 108 Delmont Ct. CITY GASTONIA  
BETWEEN Edgewood Rd. STREET &                      STREET                     


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plast.</u>	<u>116'</u>	<u>11-18-94</u>	<u>5' of 3/4" c &amp; w</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plast</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plast.</u>	<u>100'</u>			

ENTERS: 108 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 60 P.S.I.                      INCHES W.C. LOCATION 30' N of Cof Delmont Ct.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By B.S.  
MAIN-SIZE 2" C.I.                      BARE STEEL                      COATED STEEL                      PLASTIC ✓ YEAR INSTALLED 1994  
DEPTH: 3 Ft. 0 In. LOCATION 30' N of Cof Delmont Ct.

"A" P/S READING Plastic TOTAL ANODES 1# 1 17#                      L.R. #                     

REMARKS: Installed 1# Anode on Retired 3/4 c&w Service  
P.S. 40 on Existing 3/4 c&w Service Retired with 3/4 Dresser, nipple  
+ weld cap Bonded Dresser  
System Enhancement.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Plastic Riser</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY