

LOCATION 1541 Delta DR CITY Groton, CT

BETWEEN Jordache CR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>135'</u>	<u>5-24-02</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>135'</u>			

ENTERS 1541 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 393' E. of center of Jordache CR

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SW


MAIN-SIZE 6" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH 3 FT 0 IN LOCATION 30' N. of center of Delta DR

"A" P/S READING .7 TOTAL ANODES 1# 0 17# 1 LR # 126201

REMARKS 4

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	



POSTED TO GIS & BASS
BY VFM DATE 6/11/02