

LOCATION 600 Devonwood Ct. CITY GASTONIA
BETWEEN Nytle woods Dr. STREET & End of Culdesack STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>75'</u>	<u>4-17-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>65'</u>			

ENTERS: 600 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 368' N of C of Nytle wood Dr.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1991
DEPTH: 3 FT. 0 IN. LOCATION 11' E of C of Devonwood Ct.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 L.R. # 185642

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY