

LOCATION 611 Devonwood Ct CITY Astoria

BETWEEN Myrtlewood STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>82</u>	<u>6-22-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>5</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>77</u>			

ENTERS: 611 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION W side of house


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By Bennett

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 2 Ft. 6 In. LOCATION 40' W of C. Alt

"A" P/S READING _____ TOTAL ANODES 1* _____ 17* _____ L.R. # 00263318

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY