

LOCATION 176 Dixon Cir.

CITY Gastonia

BETWEEN Oak Valley Dr.

STREET &amp; S. Marleatta ST.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.						
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE:

PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C.

LOCATION

PRESSURE TEST: @ \_\_\_\_\_ PSI FOR \_\_\_\_\_ HRS. BY \_\_\_\_\_


MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1960

DEPTH: 3' FT. 0 IN. LOCATION Dixon Cir.

"A" P/S READING .990 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: Bonded insulator on existing 3/4" ctw gas service line. C.P. #1845

Readings: .990 before bond to 1.100 after bond was made.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY