

LOCATION 809 S. Dogwood CITY Gastonia  
BETWEEN 8th STREET & Garrison STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>67'</u>		<u>11-11-97</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>1'</u>	<u>11</u>	<u>59'</u>			

ENTERS: 809 BRANCHED INTO: 0  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 99' N of c of 8th


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BC

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. IN. LOCATION 16' w of c of Dogwood

"A" P/S READING plastic TOTAL ANODES 1# \_\_\_\_\_ 17# ~ L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>PR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY