

LOCATION 902 Dogwood Dr.CITY GASTONIABETWEEN 8th

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>D</u>	<u>22'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>D</u>	<u>5'</u>			<u>4-1-22</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>D</u>	<u>22'</u>			


ENTERS: 902BRANCHED INTO: 0TAP SIZE: 3/4 ser.PRESSURE 20 PSI

INCHES W.C.

LOCATION

PRESSURE TEST: @ 100 PSI FOR 64 HRS. BY EPMAIN SIZE 3/4 C.I. BARE STEEL ✓ COATED STEEL PLASTIC YEAR INSTALLED 1952DEPTH: 2 FT. 6 IN. LOCATION"A" P/S READING .5TOTAL ANODES 1# 1 17# L.R. #

REMARKS:

Tracer wire bonded to EXT 3/4 bare pipe

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY