

LOCATION 905+907 DogwoodCITY GastoniaBETWEEN Eighth StSTREET & Dogwood

STREET

	SIZE	TYPE	905 LENGTH 907		INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	126'	33'	<sup>7-7-98</sup> Tied Over		
MAIN TO PROP. LINE	3/4"	P	41'		Exist. Plastic with 41' of		
PROP. LINE TO BLDG.	3/4"	P	85'		New Plastic to New 2" main		

ENTERS: 905 DogwoodBRANCHED INTO: 907 DogwoodTAP SIZE: 3/4"PRESSURE 60 PSI

INCHES W.C.

LOCATION 18' North of Dogwood +226' East of Eighth St.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M.P.MAIN-SIZE 2"

C.I. \_\_\_\_\_


BARE STEEL \_\_\_\_\_

COATED STEEL \_\_\_\_\_

PLASTIC ☒YEAR INSTALLED 1997DEPTH: 3 FT. 6 IN.LOCATION 18' North of Dogwood"A" P/S READING Plastic

TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_

L.R. # \_\_\_\_\_

REMARKS: Tied over Exist 3/4" plastic service to New 2" main

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	P riser
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY