

LOCATION 910 S. Dogwood CITY Gastonia
BETWEEN 8th st STREET & 9th st STREET


	SIZE	TYPE	910 LENGTH 908	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	108' 74'			11-12-97
MAIN TO PROP. LINE	11	11	6' 10'			
PROP. LINE TO BLDG.	11	11	102' 64'			

ENTERS: 910 BRANCHED INTO: 908
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 293' S of c of 8th

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BC
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997
DEPTH: 3 FT. IN. LOCATION 16' E of c of Dogwood

"A" P/S READING plastic TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY