

LOCATION 7007 Dolphin st. CITY Gastonia N.C.  
BETWEEN S. New Hope Rd. STREET & Marlin st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8</u>	<u>P</u>	<u>108'</u>	<u>11.20.01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>38'</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>70'</u>			

ENTERS 7007 BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION E side of 7007


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY T. Cain

MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC        YEAR INSTALLED 2001

DEPTH 3 FT IN LOCATION S. side of Dolphin st.

"A" P/S READING N/A TOTAL ANODES 1#        17#        LR #       

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	