

LOCATION 7027 Dolphin st. CITY Gastonia
 BETWEEN Martin st. STREET & Si. New Hope Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	112'	9-9-02		
MAIN TO PROP LINE	5/8"	P	40'	"		
PROP LINE TO BLDG	5/8"	P	72'	"		

ENTERS 7027 BRANCHED INTO 0
 TAP SIZE. 3/4" PRESSURE 60 PSI INCHES W C LOCATION 377' East


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody of cat. of Martin st.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2001

DEPTH 3' FT 0" IN LOCATION 20' south of cat. of Dolphin st.

"A" P/S READING 117 TOTAL ANODES 1# 0 17# 0 LR # 00247698

REMARKS New Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	riser