

LOCATION 2237 Donnadbrook Ln

CITY Gresham

BETWEEN Fallsdale Dr

STREET & Chapel Grove Rd

STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG. | 3/4 | P | 105' | 3-21-94 | | |
| MAIN TO PROP. LINE | 3/4 | P | 7' | | | |
| PROP. LINE TO BLDG. | 3/4 | P | 98 | | | |

ENTERS: 2237 Donnadbrook Ln

BRANCHED INTO: -

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 395' E of Chapel Grove Rd


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. K. Moore

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1963

DEPTH: 2 Ft. 6 In. LOCATION 15' S. of Donnadbrook Ln

"A" P/S READING 1.6 TOTAL ANODES 1* - 17* - L.R. # 103425

REMARKS:



| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | P |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY