

LOCATION 1060 Donohoe Rd. CITY Gastonia
 BETWEEN Windercrest Ave STREET & Pope Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	23'	12-13-00		
MAIN TO PROP LINE	3/4"	P	3'			
PROP LINE TO BLDG	3/4"	P	20'			


ENTERS 1060 BRANCHED INTO
 TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 63' N. of center of Donohoe Rd.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.
 MAIN SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH 2 FT 0 IN LOCATION 13' SE of center of Windercrest Ave

"A" P/S READING 1.1 TOTAL ANODES 1# 0 17# 0 LR # 1159163

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	