

LOCATION 1002 Dornoch Rd CITY Spokane  
BETWEEN Heatherloch Dr. STREET & \_\_\_\_\_ STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>580</u>	<u>6-29-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>55</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>525</u>			

ENTERS: 1002 BRANCHED INTO:  
TAP SIZE: 3/8 PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION Side of house

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Barnett  
MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1973  
DEPTH: 2 Ft. 6 In. LOCATION 25' W of Cabt

"A" P/S READING 1.0 TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # 00279729

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY