

LOCATION 1280 DORCHESTER RD. CITY BOSTON

BETWEEN PATRICK RD. STREET & CUL-DE-SAC STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>130'</u>	<u>3-19-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>115'</u>			

ENTERS: 1280 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION SE of center of Patrick Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HUFFZALL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1987

DEPTH: 3 FT. 0 IN. LOCATION 37' SW. of center of DORCHESTER RD.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 150570

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY