

LOCATION 3400 DOVE LN.CITY GASTONIABETWEEN Quail RidgeSTREET & Bobwhite

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>59'</u>	<u>01-3-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>44'</u>			

ENTERS: 3400


BRANCHED INTO: -

TAP SIZE: 3/8PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 13' E OF QuailRidgePRESSURE TEST: @ 100 psi For 1/4 Hrs. By M. ParkerMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL 1 PLASTIC _____ YEAR INSTALLED 1971DEPTH: 3 Ft. 0 In.LOCATION 110 N OF DOVE LN"A" P/S READING 1.2

TOTAL ANODES 1# _____ 17# _____

L.R. # 592609

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-rise</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY