

LOCATION 4304 Dove Trl. CITY GASTON, N.C.

BETWEEN Birch Ln STREET B King Crowder Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>184'</u>	<u>2-23-89</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>174'</u>			

ENTERS: 4304 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 118' SE. of center of Birch Ln


PRESSURE TEST: @ 100 psi For 4 Hrs. By SK

MAIN - SIZE 2" C.I.        BARE STEEL        COATED STEEL ✓ PLASTIC        YEAR INSTALLED       

DEPTH: 3 Ft. 0 In. LOCATION 14' NE. of center of Dove Trl.

"A" P/S READING .4 TOTAL ANODES 1# 0 17# 1 L.R. # 131052

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	