


LOCATION 539 Downey Pl.CITY GASTONIABETWEEN Gardner Park DrSTREET & Whitson

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>3</u>	<u>5-14-94</u>		
MAIN TO PROP. LINE				<u>3' Plastic tie-over</u>		
PROP. LINE TO BLDG.				<u>Existing 130' C+W + 23' C+W to Plastic</u>		

ENTERS: 539 DowneyBRANCHED INTO: 601 Downey

MAIN

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 113 South ofWhitsonPRESSURE TEST: @ 100 psi For 1/4 Hrs. By K HayesMAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993DEPTH: 3 Ft. _____ In. LOCATION 12 West of Downey Pl."A" P/S READING 1.3 Both Services TOTAL ANODES 1* _____ 17* _____ L.R. # _____REMARKS: Tracer wire not Bonded to Main

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY