


LOCATION 637 DowneyCITY GASTONIABETWEEN WhitsonSTREET & Gardner Park

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>3</u>	<u>5-14-94</u>		
MAIN TO PROP. LINE				<u>Tie over Existing 95' C&W + 107' C&W</u>		
PROP. LINE TO BLDG.						

ENTERS: 637 DowneyBRANCHED INTO: 627 DowneyTAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 240 North of Gardner ParkPRESSURE TEST: @ 100 psi For 1/4 Hrs. By K HayesMAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 199DEPTH: 3 Ft. _____ In. LOCATION 12 West of Downey"A" P/S READING 1.2 Both services TOTAL ANODES 1# _____ 17# _____ L.R. # _____REMARKS: Tracer Wire Not Bonded to Main

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY