

LOCATION 640 DowneyCITY GASTONIABETWEEN Gardner ParkSTREET & Whitson

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>3</u>	<u>5-7-94</u>		
MAIN TO PROP. LINE				<u>Tie over</u>	<u>Existing 150'</u>	
PROP. LINE TO BLDG.					<u>of 3/4 Plastic</u>	

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 113' North of Gardner Park


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. _____ In. LOCATION 14' West of Downey Pl.

"A" P/S READING P. TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS: Tracer wire Bonded to Main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY