


LOCATION 641 Downey Pl.CITY GASTONIABETWEEN Gardner Park DrSTREET & Whitson Rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>3'</u>	<u>5-7-94</u>		
MAIN TO PROP. LINE			<u>Tie-over</u>	<u>Existing</u>	<u>85' C.W</u>	
PROP. LINE TO BLDG.				<u>to Plastic</u>	<u>MAIN</u>	

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 126' North ofGardner Park Dr.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K HayesMAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993DEPTH: 3 Ft. In. LOCATION 14' West of Downey Pl."A" P/S READING 1.4 TOTAL ANODES 1* _____ 17* _____ L.R. # _____REMARKS: Ins Dresser removed - Tracer wire not Bonded

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>1.4</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY