

LOCATION 1624 Drayton Ct CITY Gastonia
 BETWEEN Plantation Trl. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	44'	5-8-00		
MAIN TO PROP LINE	3/4"	P	4'			
PROP. LINE TO BLDG	3/4"	P	40'			

ENTERS. 1624 BRANCHED INTO:
 TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W C LOCATION 290' S. of center of Plantation Trl.


PRESSURE TEST: @ 100 PSI FOR 14 HRS. BY S.H.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1988

DEPTH: 3 FT 0 IN. LOCATION 18' W. of center of Drayton Hall Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 179716

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	