

LOCATION 1125 DUNBARTON CITY Easton

BETWEEN Laurel Ln STREET & Dorset STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>0'</u>	<u>Used Ext Anodeless Riser to Rehab Service 0" Pipe</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1125 BRANCHED INTO: 0

TAP SIZE: 3/4 Ser PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY af

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED _____

DEPTH: 1 FT. 6 IN. LOCATION _____

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY