

LOCATION 4901 DUNCAN LN. CITY Gastonia

BETWEEN Woodhurst CT STREET & Maple Crest DR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	48'	12-23-97		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	38'			

ENTERS: 4901 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 73' W. of center of DUNCAN LN.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstetter

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH: 3 FT. 0 IN. LOCATION 20' S. of center of Maple Crest DR.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 863179

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY