

LOCATION 655 Dundee CITY Oakton
BETWEEN Bolt STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>69'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>		<u>1-23-87</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>64'</u>			

ENTERS: 6 65 BRANCHED INTO: _____
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 105 PSI FOR 1/4 HRS. BY ED

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 77

DEPTH: 3 FT. 6 IN. LOCATION _____

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.195/1.4</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY