

LOCATION 2390 Eagle GlenCITY GastoniaBETWEEN Falcons NestSTREET & Dead End

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>111</u>	<u>7-6-98</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>"</u>	<u>41</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>70</u>			

ENTERS: 2390BRANCHED INTO: 0TAP SIZE: 3/4PRESSURE 60 PSI


INCHES W.C.

LOCATION 181' N of c ofFalcons NestPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BcMAIN-SIZE 2"C.I. BARE STEEL COATED STEEL PLASTIC ✓YEAR INSTALLED 1996DEPTH: 3' FT.

IN.

LOCATION 17' W of c of Eagle Glen"A" P/S READING PlasticTOTAL ANODES 1# - 17# -L.R. # 477580

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY