

LOCATION 2399 Eagle Glen CITY Gastonia
BETWEEN Falcons Nest STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>78'</u>	<u>7-6-98</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>70</u>			

ENTERS: 2399 BRANCHED INTO: 0
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 106' N of C of Falcons Nest


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BC

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3' FT. IN. LOCATION 17' W of C of Eagle Glen

"A" P/S READING Plastic TOTAL ANODES 1# - 17# - L.R. # 477589

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>ER</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY