

LOCATION 3612 EAST Hampton Dr. CITY GASTON, N.C.
BETWEEN Kennedy Dr. STREET & TRABERT CR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	110'	8-9-96		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	100'			

ENTERS: 3612 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 164' S. of center of Kennedy Dr.


PRESSURE TEST: @ 105 psi For 1/4 Hrs. By S. GUEFERT

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 20' W. of center of EAST Hampton Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 168057

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY