

LOCATION 3612 EAST Hampton Ct. CITY ANTONIA  
BETWEEN Kennedy Rd. STREET & Trabert Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>20'</u>	<u>2-7-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>15'</u>			

ENTERS: 3618 EAST Hampton Ct. BRANCHED INTO: 3612 EAST Hampton Ct.  
TAP SIZE: 3/4 straight Plastic Tee PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 274' S of Coy Kennedy Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

Service MAIN SIZE 3/4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 2 FT. 0 IN. LOCATION 70' W of Coy EAST Hampton Ct.

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# 0 17# 0 L.R. # 073751

REMARKS: Split Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

ENG. DEPT. USE ONLY