

LOCATION 3619 East Hampton Dr.CITY GASTONIABETWEEN KennedySTREET & TRABERT

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P.</u>	<u>132'</u>	<u>10-21-95</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>44'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>88'</u>			

ENTERS: 3619

BRANCHED INTO:

TAP SIZE: 1/2


PRESSURE

P.S.I.

INCHES W.C.

LOCATION 20' N. of Cap
E. HamptonPRESSURE TEST: @ 100 psi For 1/4 Hrs. By SPMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993DEPTH: 3 Ft. 0 In. LOCATION"A" P/S READING PTOTAL ANODES 1* 17* L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>ER</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY