

LOCATION 3625 Easthampton DR. CITY GASTONIA

BETWEEN Kennedy Dr. STREET & STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|----------|-------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>110'</u> | <u>7-13-95</u> | | |
| MAIN TO PROP. LINE | <u>3/4"</u> | <u>P</u> | <u>45'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>65'</u> | | | |

ENTERS: 3625 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 363' S. of center

of Kennedy DR.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFSHTE

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 18' W. of center of Easthampton DR.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 327155

REMARKS:



| Test Station | | |
|--|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY