

LOCATION 3643 Easthampton DR CITY Gastonia  
BETWEEN Kennedy Rd STREET & Trebert Cr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>110'</u>	<u>5-7-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>65'</u>			

ENTERS: 3643 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 314' N. of center of Trebert Cr

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hufferdinger  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996  
DEPTH: 3 FT. 0 IN. LOCATION 18' W. of center of Easthampton Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 275361

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY