

LOCATION 3648 East Hampton Dr. CITY Castroville

BETWEEN TRA Bert STREET & Kennedy Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>74'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>	<u>10-5-96</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>69'</u>			

ENTERS: 3648 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION


PRESSURE TEST: @ 105 PSI FOR 44 HRS. BY EP

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1983

DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING P TOTAL ANODES 1# 17 # \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.45 V</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY