

LOCATION 3654 Easthampton Dr. CITY Castroville

BETWEEN Trabert Ct. STREET & Kennedy Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4'</u>	<u>P</u>	<u>108'</u>	<u>3-4-97</u>		
MAIN TO PROP. LINE	<u>3/4'</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4'</u>	<u>P</u>	<u>98'</u>			

ENTERS: 3654 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 130' N. of center of

Trabert Ct.


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY S. Chubbuck

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH: 3 FT. 0 IN. LOCATION 18' W. of center of Easthampton Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 113693

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY