

Easthampton

LOCATION 3660 East Hampton Dr.

CITY Glastonbury

BETWEEN Kennedy Rd.

STREET & TRABERT CT

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	69'			
MAIN TO PROP. LINE	3/4	P	5'	10-5-96		
PROP. LINE TO BLDG.	3/4	P	64'			

ENTERS: 3660

BRANCHED INTO: 0

TAP SIZE: 1/2

PRESSURE 60 PSI

INCHES W.C.

LOCATION

PRESSURE TEST: @ 105 PSI FOR 114 HRS. BY EP

MAIN-SIZE 2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED 1993

DEPTH: 3 FT. 0

IN.

LOCATION


"A" P/S READING

TOTAL ANODES 1#

17#

L.R. #

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	0.155
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY