

LOCATION 4316 Eastridge Dr. CITY GASTONIA

BETWEEN Old Field Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	816'	9-5-96		
MAIN TO PROP. LINE	3/4"	P	38'			
PROP. LINE TO BLDG.	3/4"	P	86'			

ENTERS: 4316 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 65' W. of center of Old Field Rd.


PRESSURE TEST: @ 100 psi For 44 Hrs. By S. Huff & Beth

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 Ft. 0 In. LOCATION 12' N. of center of Eastridge Dr.

"A" P/S READING _____ P TOTAL ANODES 1* 0 17* 0 L.R. # 445958

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY