

LOCATION 4385 East Ridge Dr. CITY GASTONIA
BETWEEN Harper Rd. STREET & FIRMAN STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>105'</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>65'</u>			

ENTERS 4385 BRANCHED INTO C
TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 208' 50' E of Harper Rd.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY R

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1906

DEPTH 3' FT 0 IN LOCATION 13' E of E of East Ridge Dr.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Rwer</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>