

LOCATION 548 Eastwood Dr. CITY GASTOWIA  
BETWEEN FLANAGAN LANE STREET & GARDNER PARK Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>5'</u>	<u>4-23-94</u>	<u>Tied over 160' Existing</u>	
MAIN TO PROP. LINE					<u>3/4 C/W</u>	
PROP. LINE TO BLDG.						


ENTERS: 548 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 213' W of C of FLANAGAN LANE

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL  
MAIN-SIZE 2" C.I.     BARE STEEL     COATED STEEL     PLASTIC ✓ YEAR INSTALLED 1993  
DEPTH: 3 Ft. 6 In. LOCATION 16' S of C of Eastwood Dr.

"A" P/S READING P TOTAL ANODES 1\*     17\*     L.R. #    

REMARKS: Tied Trace wire off at Tee  
Bonded - Dresser.

Bare Main Replacement  
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u> <u>.95</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY