

LOCATION 553 Eastwood Dr. CITY GASTONIA  
BETWEEN FLANAGAN STREET & GARDNER PARK Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>0'</u>	<u>5-7-94</u>	<u>Tied over 110' Existing</u>	
MAIN TO PROP. LINE					<u>3/4 Plastic</u>	
PROP. LINE TO BLDG.						

ENTERS: 553 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 214' W of C of FLANAGAN ST


PRESSURE TEST: @ 100 psi For 24 Hrs. By RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 14' S of C of Eastwood Dr.

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY