

LOCATION 600 Eastwood CITY Lansonia  
BETWEEN Flanagan STREET & London Park Dr. STREET

	SIZE	TYPE	P	LENGTH	5	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>		<u>5</u>	<u>160</u>		<u>4/94</u>		
MAIN TO PROP. LINE	<u>3/4</u>		<u>5</u>	<u>41</u>				
PROP. LINE TO BLDG.	<u>3/4</u>		<u>0</u>	<u>119</u>				

ENTERS: 600 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION Widened Horse

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Bennett


MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1993

DEPTH: 2 Ft. 6 In. LOCATION 16' 8" J.C. H.H.

"A" P/S READING .30 TOTAL ANODES 1# 1 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

~~Bare~~ Main Replacement  
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>1.50</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY