


LOCATION 610 Eastwood DrCITY GastoniaBETWEEN Flanagans LnSTREET & Gardner park Dr.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>			<u>Tied over 170' Ext 3/4</u>	
MAIN TO PROP. LINE			<u>5"</u>	<u>4-30-94</u>	<u>Plastic Service to Ext</u>	
PROP. LINE TO BLDG.					<u>2" Plastic Main</u>	

ENTERS: 610BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION N. Side of 610PRESSURE TEST: @ 100 psi For 114 Hrs. By BCMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993DEPTH: 3 Ft. In. LOCATION 15' S of C of Eastwood"A" P/S READING plastic TOTAL ANODES 1* - 17* - L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY