

LOCATION 645 Eastwood CITY Houston

BETWEEN Thurman Park Rd STREET & Flanagan STREET

	SIZE	TYPE	5 LENGTH	P	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4		3	178	<u>Tied over</u> <u>4-30-94</u>		
MAIN TO PROP. LINE	3/4		3	35			
PROP. LINE TO BLDG.	3/4		0	143			

ENTERS: 645 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION East of house

PRESSURE TEST: @ 100 psi For 48 Hrs. By Bennett


MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1983

DEPTH: 2 Ft. 6 In. LOCATION 13' W of Cyl

"A" P/S READING .52 TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:

Bare Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	1010
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY