

LOCATION 1209 Edgelyield CITY GASTONIA
BETWEEN CAROLINA STREET & PARK LANE STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>D</u>	<u>91</u>		<u>03/06/98</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>8</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>83</u>			

ENTERS: 1209 BRANCHED INTO: 0
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 209' NORTH OF PARK LANE

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY NS
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1998
DEPTH: 3 FT IN LOCATION 18' west of Edgelyield

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Tied over 91' Existing 3/4" PLASTIC Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>PR</u>	<u>D</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY