

LOCATION 1117 Edgewood Ave CITY GASTONIA

BETWEEN FAIRFIELD DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>103'</u>	<u>tie over</u> <u>6/18/94</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1117 BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION South side of 1117


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By DT

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 3 Ft. In. LOCATION EAST side of Edgewood Ave

"A" P/S READING TOTAL ANODES 1* 0 17* 0 L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY