

LOCATION 1127 EdgemontCITY GASTONIABETWEEN Fairfield Dr

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>33'</u>	<u>6-11-94</u>	<u>33' Plastic Tie-over</u>	
MAIN TO PROP. LINE					<u>Existing</u>	<u>104 Plastic</u>
PROP. LINE TO BLDG.					<u>to 2" Plastic Main</u>	

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 358 West of
Fairfield Dr


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By R Hayes

MAIN-SIZE 2 C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. In. LOCATION 12 South of Edgemont

"A" P/S READING P. TOTAL ANODES 1# — 17# — L.R. # —

REMARKS: Tracer wire Bonded



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY